

MEMORANDUM

DATE: 11/08/10
TO: PROSPECTIVE BIODIESEL TANK PROJECT VENDORS
FROM: ROBIN JAMES, CHATHAM COUNTY PURCHASING AGENT
CC: SONYA GILLILAND, DAN LAMONTAGNE

ADDENDUM NO. 1

I've had some late questions come in on the Biodiesel Tank Installation for Chatham County that need a response. This response is to benefit all known interested parties of the project.

Questions:

#1 The specification calls for a double wall tank. Does this include two emergency vents?

1A. The bid specification requires one 6" emergency vent and a 2" updraft vent. As far as the Fire Marshall's Office can advise on this item, it is sufficient for the requirement.

#2. The scope of work indicated connection to an existing junction box while the electrician scope called for installation of a junction box. Which is correct?

2A. Connection to an existing junction box.

#3. What is the distance to the junction box?

3A. The exact distance will be determined by the Fire Marshall at the time of filling the site plan during the required permitting process. It is estimated the distance will be no more than ten feet from the existing junction box.

#4. What is the required amperage for the mixer and pump?

4A. The breaker box available is a 40 amp breaker. The pump on the current diesel tank is 7 ½ amp load to the breaker box. The amperage for the new mixer and pump has not been predetermined but should not overload the current breaker.

Due to the essence of time, this will be the only addendum provided for this project. If you find some additional information is needed, please attach this in addition to the bid form. The County will verify information. The County reserves the right to consider or not information that is not required by additional North Carolina or County Laws.