

Addendum No 2

Solid Waste & Recycling Concrete Pads Replacement
Attention All Potential Contractors
February 27, 2015



A few last questions arrived prior to the deadline for submittal of questions.

- Q.1.) Is the #5 rebar 1' o.c. (under Scope of Work) intended for both ways?
A.1.) Yes
-
- Q.2.) Do you know if and how the existing slabs are reinforced?
A.2.) Do not know
-
- Q.3.) Do you know the existing concrete thickness? If the existing slabs are other than 8", filling or cutting needs to be allowed for.
A.3.) Original plans show 8".
-
- Q.4.) Please confirm that disposal of concrete must be at one of the dumpsites listed on the C & D website.
A.4.) Yes.

The deadline for bids is March 3, 2015, 2:00 PM EST. Bids will be opened and read in the West Wing Conference Room located in the Finance Wing of the Annex Building at 12 East Street, Pittsboro, NC 27312.